

25X1A

25X1A

25 July 63

REPLY TO
ATTN OF:

24 July 1963

TO :

SUBJECT: Request for Changes in Electrical Wiring of Kitchen and Pantry

References: DWG, E-2, Sht 22 of 25, Electrical Power Plan for Operations Bldg

1. It is requested that the [redacted] make the necessary arrangements for the following change in the electrical plan for the kitchen and pantry in the main operations bldg. These changes represent the minimum requirements necessary to provide adequate circuitry for food storage, preparation, and use of electrical appliances:

25X1A

a. Required addition of one (1) grounding-type 2 P, 15A, 125V, Duplex convenience outlet on the east wall of the pantry adjacent to the similar outlet shown on DWG E-2, Kitchen Electrical Partial Plan

b. Required addition of two (2), 1 P 50A frame, 20A trip breakers in the spare spaces which are already provided in panelboard "PA" as shown on DWG E-2.

c. The following wire circuiting changes are also required:

- (1) Circuit "PA-1": Delete convenience outlets on the east and west walls of the south side of the kitchen, and on the east wall of the south side of the pantry area. This should leave only the hood vent fan and the convenience outlets in the north side of the kitchen area ON THIS CIRCUIT.
- (2) Add new circuit "PA-5" and connect new convenience outlet as discussed in paragraph 1a above to one of the two new circuit breakers mentioned in paragraph 1b above.
- (3) Add new circuit "PA-6" and connect remaining convenience outlets in Pantry and the two (2) convenience outlets on the south side of the kitchen to the other remaining new circuit breaker.
- (4) Also required necessary changes in conduit and wiring to effect the above additions and changes.

25X1A

2. It is requested that [redacted] pass copies of this memorandum to the A&S Inspector and the contractor as indicated on the distribution below.

~~SECRET~~

DISTRIBUTION:

25X1A

Orig and 1cc

A&S Inspector, 1cc
The Contractor, 1cc

CONFIDENTIAL